



कार्यालय, नगर पालिक निगम, कोरबा (छ.ग.)

जलप्रदाय शाखा :- साकेत भवन आई.टी.आई. चौक, कोरबा (छ.ग.)

मु.का. दूरभाष : 221288, 222672, फ़ैक्स : 07759-22929, पो. वावस नं. : 12 पिन कोड : 495677

Website : www.Korbamunicipal.in Email : mck.watersupply@gmail.com

फा.क्र./1208/ज.प्र.स./2020/

कोरबा, दिनांक 21.09.2020


सिस्टम निविदा क. 67951 निविदा आमंत्रण सूचना

नगर पालिक निगम, कोरबा द्वारा निम्नलिखित कार्य हेतु व्यवसाय के संबंधित प्रतिष्ठित निर्माता कंपनी, अनुभवी निविदाकार अथवा अधिकृत विक्रेताओं से शोड्यूल अनुसार आईटम दरों पर ई-टेंडरिंग के माध्यम से निविदा आमंत्रित की जाती है :-

क	कार्य का नाम	प्राक्कलन राशि (राशि लाख में)	धरोहर राशि	कार्यावधि	निविदा खुलने की तिथि
1	जल शुद्धिकरण कार्य हेतु रासायनिक सामग्री की खरीदी। (वार्षिक दर पर)	-	20,000/-	01 वर्ष	15.10.2020 से ..


शर्त :-

1. निविदा प्रपत्र की ई-प्रोक्युरमेंट (E-Tendring) के माध्यम से ही स्वीकार किये जाएंगे। निर्धारित तिथि को सायं 3.00 बजे के पश्चात प्राप्त निविदाओं पर विचार नहीं किया जाएगा।
2. जिन ठेकेदारों/प्रदायकर्ताओं द्वारा नगर पालिक निगम (साडा) के किसी ठेके के कार्य में अनुबंध के अनुरूप कार्य न किया गया हो अथवा नगर पालिक निगम (साडा) के हित के विरुद्ध कार्य किया गया हो उन्हें निविदा भरने की पात्रता नहीं होगी।
3. निविदा प्राप्त करने के इच्छुक ठेकेदारों/प्रदायकर्ताओं को आवेदन के साथ निर्माता कंपनी/अधिकृत विक्रेता संबंधी प्रमाण पत्र की प्रमाणित प्रतिलिपि ऑनरशीप यदि साझेदारी फर्म हो तो उसका प्रमाण पत्र (पार्टनरशीप डीड) की सत्य प्रतिलिपि, पूर्व में इस प्रकार के किये गये कार्यों का अनुभव प्रमाण पत्रों की जानकारी, आयकर प्रमाण पत्र/पैन नं. एवं जी.एस.टी. प्रमाण पत्र एवं अमानत राशि एफ.डी.आर/टी.डी.आर जो आयुक्त नगर पालिक निगम कोरबा के नाम पर देय होगा, स्कैन कर बेवसाइट पर अपलोड करना अनिवार्य होगा।
4. दर निर्धारण पश्चात् किसी अनुबंधित निविदाकार एवं प्रदायकर्ता से सामग्री कृय करने का अधिकार संस्था के पास सुरक्षित रहेगा।
5. प्रदाय की गई सामग्री का गुणवत्ता परीक्षण रिपोर्ट भुगतान पूर्व देयक के साथ संलग्न करना अनिवार्य होगा। अन्यथा भुगतान करना संभव नहीं होगा।
6. निविदा प्रपत्र उन्ही ठेकेदारों/प्रदायकर्ताओं को दिया जावेगा। जिन्हे इस प्रकार के कार्य का अनुभव हों।
7. निविदा प्रपत्र अहस्तांतरणीय होगी एवं सशर्त निविदाओं पर विचार नहीं किया जावेगा।
8. बिना कारण बताए स्वीकृत/अस्वीकृत या पूर्ण रूप से अमान्य करने का अधिकार सक्षम अधिकारी को रहेगा।
9. किसी भी तरह की विवाद की स्थिति में अंतिम निर्णय लेने का अधिकार सक्षम अधिकारी के पास सुरक्षित रहेगा।
10. उपरोक्त निविदा सूचना की विस्तृत प्रति नगर पालिक निगम कोरबा की वेब साइट www.korbamunicipal.in पर भी यह टेन्डर उपलब्ध है।
11. अन्य सूचनाएं नगर पालिक निगम साकेत भवन रामपुर कोरबा कार्यालय से प्राप्त की जा सकती है


कार्यपालन अभियंता
नगर पालिक निगम
कोरबा (छ.ग.)

Date-Time Detail(s)

Seq. No.	Nagar Nigam Stage	Contractor Stage	Start		Expiry		Remarks
			Date	Time	Date	Time	
1	Release Tender		21.09.20	10.30	21.09.20	18.30	Release Tender
2		Bid Submission	21.09.20	18.30	14.10.20	17.30	
3	Tender Open		15.10.20	10.30	--	--	



**EXECUTIVE ENGINEER
KORBA (CG)**

[Signature] For, Commissioner Korba (C.G.)

OFFICE OF THE MUNICIPAL CORPORATION KORBA (C.G)


**Estimate :- Annual Rate Contract for supply of Chemical Item for Water Supply
Central Stores**


S.N	Name of Items	Unit	Qty.	Rate	Amount
1	Supply of Bleaching powder grade-I Chlorine Content not less than 34% as per IS Specification for Chlorination of Drinking water.	MT	1		
2	Supply of poly Alluminium chloride (PAC) powder AC/100s for drinking water purification As per Below Specification.				
	a) Alumina sa Al_2O_3 % (w/w)- 29.0 + 1.0				
	b) Bulk Density/Specific Gravity at 20 ⁰ C - 0.75+0.1	Mt.	1.00		
	c) pH of aqueous Solution (w/v) 3.5-5.0 (1%)				
	d) Chloride% (w/v) - 31.0+2.0				
	e) Sulphate % max. - 10.0				
	f) Basicity % - 40.0 + 5.0				
	g) Mercury & Lead (ppm) - ND				
3	Supply of non ferric alum (Aluminium sulphate) confirming to IS 260/969 with latest amendment				
	a) Alumina - 17%				
	b) Insoluble mater 0.3%				
	c) IS Chemical composition $Al_2(SO_4)_3 \cdot 12.5 H_2O$	Mt.	1		
	d) Iron content Fe 0.1%				
	e) Minimum Al Content 16.6%				
	f) PH of 5% Slution 2.8%				
4	Supply of Farrie Alum (Aluminium sulphate) as per IS 299/1989 IV revision with additional requirement for purification of driking water	Mt.	1		
5	Supply of Salt for Electrochlorinator machine.	MT.	1		
6	Supply of filter send in jute bags sand content following shape size & quality.				
	a) Sand Should be hard & resistant Quartz OR Quartzit & free of caly fine particle soft grains dirt of every description.				
	b) Effective size small be 0.45 mm to 0.70 mm.				
	c) Uniomity coeffient not be more than 1.7 not less than 1.3				
	d) I geitions loss should not exceed 0.7% by weight.	Cum	1		
	e) Souble fration in hydro chloric acid shal not exceed 5% by weight.				
	f) Bilic content should be in range between 2.55 to 2.65				
	g) Wearing loss shall not eccceed 3% the sand for filter media to be procured from river Narmada at Hosangabad or Barakar west Bangal.				


7	Supply of Filter gravel As Per IS Specification Shepe - Spherical, Free Form Impurities Size 25 mm -40 mm " Packing 40/50 Kg HDPE Bags	Cum	1
8	Supply of filter send in jute bags sand content following shape size & quality.	Cum	1
	a) Sand Should be hard & resistant Quartz OR Quartzit & free of caly fine particle soft grains dirt of every description.		
	b) Effective size small be 0.45 mm to 0.70 mm.		
	c) Uniomity coeffient not be more than 1.7 not less than 1.3		
	d) I geitions loss should not exceed 0.7% by weight.		
	e) Souble fration in hydro chloric acid shal not exceed 5% by weight.		
	f) Bilic content should be in range between 2.55 to 2.65		
	g) Wearing loss shall not exceed 3% the sand for filter media to be pro cured from river Narmada at Hosangabad or Barakar west Bangal.		
9	Supply of Filter gravel As Per IS Specification Shepe - Spherical, Free Form Impurities Size 1.52mm -3.50mm " Packing 40/50 Kg HDPE Bags	Cum	1
10	Supply of Chlorine Tablet for Drinking water (each packet 1000 Tablets)	packet	1
11	Supply of Sodium Hypochloride liqiud Chlorisafe (Each Bottle 30 ML) for chlorination of Drinking water	Bottle	1
12	H2s bottal balcteriological test kit for bacteria test at site	Each	1
13	supply of field test kit complete set including universal indicator, Otolodine solution, regreat for iran, floride, nitrare, hardness, PH, chlorine, turbiditoy test.		1

Terms & Conditions :-

- 1 Supplier shall obtain approval (By supplying Samples) for store incharge regarding quality of material to
- 2 The Material must be supplied at central stors/water supply store Nagar Palik Nigam Korba (C.G.)
- 3 The supplied material are confirme relevent IS specification and code No. materail shall not be Accepted
- 4 Supplier will be provide test report form Govt. Testing Laboratory of supplied material at his own cost to
- 5 NPN Abbreviates Nagar Palik Nigam Korba


Sub Engineer
Municipal Corporation
Korba (C.G.)


Asstt Engineer
Municipal Corporation
Korba (C.G.)


Executive Engineer
Municipal Corporation
Korba (C.G.)